

BMP Summary Sheet

MS4 Name: University of Minnesota, Twin Cities

Minimum Control Measure: 6-POLLUTION PREVENTION/GOOD HOUSEKEEPING

Unique BMP Identification Number: 6B.02 (MS4 2020: 21.10, 21.11, 21.13)

BMP Title: Inspection & Maintenance of MS4 Outfalls

BMP Description:

For stormwater outfalls (excluding underground outfalls) to properly function, they need to be routinely inspected and maintained.

Stormwater outfalls are inspected annually for structural integrity, function, maintenance needs, and any signs of illicit discharges. Maintenance items are completed within one year of discovery, when feasible. Priority is given to maintenance items that improve or maintain structural integrity or proper function of the infrastructure. Any maintenance items that are not feasible to be completed within one year are documented.

When feasible, inspections take place during dry weather conditions (a minimum of 72 hours after a precipitation event) and in the fall when the foliage is going dormant, but before measurable snow.

Annual inspections are completed using the outfalls inspection form, which is documented and recorded in GIS.

Measurable Goals:

Number of MS4 outfalls

Number of MS4 outfalls inspected, annually

Timeline/Implementation Schedule:

Inspect all MS4 outfalls, annually

Specific Components and Notes:

PM-WSWR-007: Annual Inspection of MS4 Outfalls

04 sw Manhole and Outfall Inspections, GIS map

Responsible Party for this BMP:

Name: Catherine Abene, P.E.

Department: Principal Civil Engineer, Energy Management

E-mail: abene@umn.edu